



NOTES:

- 1.) BLACK PE TUBING (150 PSI) W/ PURPLE STRIPE OR PURPLE TUBING. NO PE WRAP. PROVIDE PURPLE MARKING WITH PURPLE 3M TAPE OR EQUAL.
- 2.) ALL FITTINGS AND LINES 1-1/2" UNLESS SPECIFIED OTHERWISE.
- 3.) NON-POTABLE WATER "DO-NOT-DRINK" SIGNAGE (AS PROVIDED BY LMUD) MUST BE DISPLAYED NEAR METER BOX.
- 4.) PROVIDE 1-1/2" PRESSURE REDUCING VALVE BY WATTS OR EQUAL UNLESS OTHERWISE SPECIFIED.
- 5.) LMUD SHALL FURNISH METER BOX LID TO CONTRACTOR AT COST. LID SHALL HAVE "LAKEWAY MUNICIPAL UTILITY DISTRICT".
- 6.) BOX LIDS SHALL BE PAINTED SAFETY PURPLE.



LAKEWAY MUNICIPAL UTILITY DISTRICT
LAKEWAY, TEXAS

Scale: NTS			
Date Issued:		July 29, 2009	
Rev.#	Date	By	Remarks
3	11/22/22	CC	CORRECTIONS

**RECLAIMED WATER
IRRIGATION SERVICE**

**STANDARD
DETAIL
R-1**